



RESIDENTIAL REPLACEMENT FORCED AIR FUEL FIRED APPLIANCE

NEW CASTLE COUNTY

2015 IMC Self-Certification Form

DEPARTMENT OF LAND USE
87 READS WAY, NEW CASTLE, DE 19720
PHONE: 302-395-5400 • WWW.NCCDELU.ORG

5/26/15
REVISED 4/6/2017
CODE "RRA"

This certification form shall be signed by the Licensed Contractor who performed the installation. Completed forms must be forwarded to the New Castle County Inspections Section at buildinginspections@nccde.org immediately following the installation.

LOT # _____ SUBDIVISION _____ TAX PARCEL _____
PROPERTY ADDRESS _____
HVAC PERMIT # _____

CHECKLIST

Installations shall comply with all applicable New Castle County adopted codes

Specs: _____ BTU Manuf. _____ Model # _____

Fuel type Natural Gas LP Oil With A/C A/C not applicable

General / Inspection checklist

Passed N/A

- Manufacturer's instructions left with appliance IMC 304.1
- Manufacturer's name, model, etc affixed to appliance IMC 301.6
- Appliance installed in accordance with permits Chapter 6 6.03.013
- Lighting fixture installed (attic & under floor spaces) IMC 306
- Electrical work installed & inspected if applicable DE Title 24 Ch. 14
- Chimney and/or vent connector in good condition or replaced IMC 803
- Chimney and/or vent connector minimally pitched & properly sized IMC 803.10.5, 801.6
- Masonry chimneys lined per IMC 801.16, IFGC 504.2.7, 504.2.9
- Direct-vent, integral & mechanical draft systems installed to code IMC 804
- Condensate disposal installed per code IMC 307
- Access and service space per code IMC 306
- Piping supported per code IMC 305
- Air filters located, installed, and of approved type IMC 605

Gas

Passed N/A

- Shut off valves installed IFGC 409.1
- Fuel gas piping inspected if required IFGC 406.1
- Clearance to combustibles IMC 304.9, 308
- Combustion air provided IMC 701
- Ignition source elevated in hazardous locations IMC 304.3
- Oil tank removed if required

Oil

Passed N/A

- Shut off valves installed IMC 1307
- Fuel oil piping complies with code IMC 1302
- Clearance to combustibles meets code IMC 304.9, 308
- Combustion air provided IMC 701
- Ignition source elevated in hazardous locations IMC 304.3
- Barometric damper installed IMC 803.6
- Fuel oil tank and piping installed per code IMC Chapter 13

Building Permit Holder's Signature (or Authorized Rep.)

Date

Print Name

NCC Contractor
Registration # (if
applicable)

Please be aware that New Castle County will continue to reserve the right to perform inspections on the replacement appliance installation. Licensed contractors who certify installations that are later found to not meet minimum code standards, will have their self-certification privilege revoked. Should you have any questions regarding this matter, please feel free to contact the Inspections Office at 302-395-5572.