



NEW CASTLE COUNTY

RESIDENTIAL REPLACEMENT WATER HEATER
2018 IPC Self-Certification Form

DEPARTMENT OF LAND USE
87 READS WAY, NEW CASTLE, DE 19720
PHONE: 302-395-5400 • WWW.NCCDELU.ORG

1/12/21
CODE "RRA"

This certification form shall be signed by the Licensed Contractor who performed the installation. Completed forms must be forwarded to the New Castle County Inspections Section at buildinginspections@nccde.org immediately following the installation.

LOT # _____ SUBDIVISION _____ TAX PARCEL _____

PROPERTY ADDRESS _____

PLUMBING PERMIT # _____

CHECKLIST
Installations shall comply with all approved applicable codes

Water Heater Specs: Gas Oil Electric Size _____ gal. Manuf. _____ Model # _____

Passed

| | |
|--|----------------------------------|
| <input type="checkbox"/> Full open valve on cold water supply section | IPC 606.1 |
| <input type="checkbox"/> Pressure relief valve and temperature relief installed | IPC 504.4 |
| <input type="checkbox"/> Relief valve piping must be full size and comply fully with | IPC 504.6, DE Plumbing Code 2.18 |
| <input type="checkbox"/> Gas line checked for leaks at appliance | IFGC 406 |
| <input type="checkbox"/> Gas line and gas valve up to code | IFGC Chap. 4 |
| <input type="checkbox"/> Existing chimney cleaned and sized properly | IFGC 501.15 |
| <input type="checkbox"/> Manufacturer's installation information avail on site | NCC Chap. 6 6.03.013 (B),(5a) |
| <input type="checkbox"/> Copy of this certification left on job site | Chap 6 Sec 6.03.013 (B),(6) |

Building Permit Holder's Signature (or Authorized Rep.)

Date

Print Name

NCC Contractor
Registration # (if
applicable)

Please be aware that New Castle County will continue to reserve the right to perform inspections on the replacement appliance installation. Licensed contractors who certify installations that are later found to not meet minimum code standards, will have their self-certification privilege revoked. Should you have any questions regarding this matter, please feel free to contact the Inspections Office at 302-395-5572.