

Department of Public Works Sewer Use Design Flows

- ✚ Effective July 31, 2000
- ✚ June 24, 2003 (revision to school and day care design flow criteria)
- ✚ August 24, 2005 (revision to school design flow criteria)
- ✚ July 1, 2007 (revision to day care and church criteria)
- ✚ February 28, 2022 (revision to warehouse/fulfillment center criteria, retail, contractor office, restaurant, tavern; inclusion of beauty salon, barber shop, car wash and laundromat)

Use	Gallons Per Day (gpd)
1. House Unit: single family detached	300
2. House Unit: single family attached	250
3. House Unit: apartment	200
4. Office/ Bank/ Retail	0.10 per square foot
5. Warehouse (with process use)	0.10 per square foot (or proposed water use)
6. Warehouse (fulfillment/logistics, contractor office/shop)	12.5 gpd/ required parking space
7. Restaurant/Tavern	25 per seat
8. School/Day care	7.5 per student/12.5 per employee
9. Motel	50 per room
10. Hotel	50 per room plus ancillary uses
11. Hospital	150 per bed
12. Nursing & assisted living facilities	100 per person
13. Assembly Halls	2.50 per seat
14. Church	4 per pew seat
15. Employee for factory, service use, etc.	12.5 per employee
16. Country Clubs	50 per member
17. Beauty Salon	125 per chair (may present water use records for review)
18. Barber Shop	50 per chair (may present water use records for review)
19. Car Wash, Laundromat	Evaluated on an individual basis