

Sewer Use Design Flows

Department of Special Services

July 31, 2000

June 24, 2003 (revision to school and day care design flow criteria)

August 24, 2005 (revision to school design flow criteria)

July 1, 2007 (revision to day care and church criteria)

<u>Use</u>	<u>Gallons Per Day (gpd)</u>
1. House Unit: single family detached	300
2. House Unit: single family attached	250
3. House Unit: apartment	200
4. Office, Bank	0.10 per square foot
5. Warehouse (without flow data)	0.10 per square foot
6. Restaurant: typical	25 per seat
7. Restaurant: 24 hours or along freeway	50 per seat
8. Tavern, bar with limited food service	25 per seat
9. School	7.5 per student/12.5 per employee
10. Day Care	7.5 per student/12.5 per employee
11. Motel	50 per room
12. Hotel	50 per room plus ancillary uses
13. Hospital	150 per bed
14. Nursing & assisted living facilities	100 per person
15. Assembly Halls	2.50 per seat
16. Church	4 per pew seat
17. Employee for factory, service use, etc.	12.5 per employee
18. Country Clubs	50 per member